



**CITY OF GLOBE
LIGHTNING AND SURGE PROTECTION SERVICES
INVITATION FOR BIDS NO. GS-2018-0005**

ADDENDUM #3:

DATE 04-17-18

CHANGES TO INVITATION FOR BIDS NO. GS-2018-0005:

Please take note of the following change to Invitation for Bid No. GS-2018-0005 – Lightning and Surge Protection Services. This addendum must be acknowledged and included with your bid submission.

1. **QUESTION:** What final certification is required for this project? Is a UL certification required for all six structures only or a LPI and UL certification for all six structures required? Based on the wording it appears that a UL and LPI certification is required. Please advise. Additionally, is the Master Label Certification for each structure supposed to be to UL96A only or is a Master Label Certification required for both UL96A and NFPA 780?

ANSWER: Per Specification Section 16062, Paragraph 1.1.A.1, "... Each area/system shall be UL labeled and shall be designed and installed in compliance with provisions of UL-96A and NFPA-780."

NOTE: Final questions, if any, are due by 3:00 P.M. on Friday, April 20, 2018.

THE BID DUE DATE AND TIME HAS BEEN CHANGED TO WEDNESDAY, APRIL 25, 2018 AT 2:30 P.M. IN THE CITY HALL CONFERENCE ROOM AT 150 N. PINE STREET, GLOBE, AZ 85501.

This concludes Addendum #3.